

M SERIES ERV SUGGESTED SPECIFICATION

Furnish and install, at locations shown on plans or in accordance with schedule, mechanical cooling and/or heating system complete with a stand-alone Energy Recovery Ventilator (ERV). The Energy Recovery Ventilator will contain an energy recovery component rated in accordance with ARI Standard 1060 with ratings certified by ARI. ERV shall be designed for ducting to the A/C (rooftop, upflow, horizontal) unit into the duct system of an air conditioning unit or as a stand-alone unit with its own duct system. The cabinet shall be galvanized material with a powder coated paint finish electrostatically bonded to the metal. Cabinet panels where conditioned air is handled shall be fully insulated to prevent condensation and minimize sound. Openings shall be provided for duct connections. Lifting devices shall be provided for rigging. Test ports shall be provided so airflow can be measured across the energy recovery wheel. The intake and exhaust air blowers of the ERV shall contain a centrifugal forward curved blower. They shall have ball bearings with adjustable belt drive and motor mount base shall permit ease of motor change-over and belt tension adjustment.

The energy recovery device shall be a rotary heat exchanger per ARI Standard 1060 description. The device will be an enthalpy wheel coated with a silica gel desiccant by a patented process without the use of binders or adhesives which may plug the desiccant aperture. The substrate shall be a lightweight polymer. Desiccant shall not dissolve or deliquesce in the presence of water or high humidity. The wheel shall be easily cleanable with water and/or alkaline based coil cleaning solution. In all size units the wheel shall be provided with removable segments for cleaning and maintenance.

All diameter and perimeter seals shall be provided. The energy recovery cassette shall be an Underwriters Laboratories Recognized Component for electrical and fire safety. ERV unit to have 2" pleated filters on the intake and return air sides. ERV shall be provided with a single point power connection for high voltage. Energy Recovery Ventilator shall be Ruskin "M" Series for indoor use in a side-by-side configuration.

OPTIONS (specifier select as required)

Low Ambient Kit - Furnish and install a low ambient kit to prevent frost formation on the energy recovery wheel.

Motorized Intake Air Damper - Furnish and install motorized intake air damper.

Stop-Start-Jog - Furnish and install stop-start-jog controls to stop wheel rotation during economizer cycle operation.

Disconnect - Furnish disconnect box for field installation.

Dirty Filter Switch - Furnish and install dirty filter switch.

Rotation Sensor - Furnish and install rotation sensor to verify wheel rotation.

Pressure Sensor - Furnish and install pressure sensor to confirm airflow performance.

York continually strives to improve our products, and reserves the right to change product design and specification without notice.